



9777 Las Vegas Boulevard South
Las Vegas, Nevada 89183
Telephone: (702) 797-8060

2019 STATE & LOCAL FIRE CODES

South Point Management and staff are looking forward to the pleasure of your visit. We ask that you please comply with State and Local Fire Codes and the South Point building policies.

- **ALL EXHIBIT SHOWS ARE REQUIRED TO HAVE AN APPROVED FIRE MARSHALL PERMIT.**
- **NOTICE: SMOKING IS PROHIBITED IN EXHIBIT AREAS.**
- All materials used in exhibit construction, decoration, or as a temporary cover **MUST BE CERTIFIED AS FLAME RETARDANT** and a sample must be available for testing.
- ALL EXITS AND EXIT AISLES must be kept clear and unobstructed. Designated "No Freight" aisles must be maintained clear of crates and exhibit materials during move-in and move-out.
- ALL FIRE HOSE RACKS, FIRE EXTINGUISHERS AND EMERGENCY EXITS must be visible and accessible.
- NO STORAGE OF ANY KIND IS ALLOWED BEHIND BOOTHS OR NEAR ELECTRICAL EQUIPMENT. Materials for handouts must be limited to a one-day supply and stored neatly within the booth. **IF NOT REMOVED BY SHOW OPENING, SHOW DECORATOR WILL REMOVE AND STORE AT EXHIBITOR'S EXPENSE.**
- HARD WALLS MUST BE NINE (9) INCHES FROM PROPERTY LINE FOR ACCESS TO ELECTRICAL EQUIPMENT.
- All 110-VOLT EXTENSION CORDS shall be three-wire (grounded), #14 or larger AWG, copper wire. Connectors must not be supported by cords.
- CUBE TAP ADAPTERS ARE PROHIBITED. Multi-plug connectors must be UL approved with built-in overload protection.
- ELECTRICAL WORK UNDER CARPETS must be done, or supervised by the South Point. Round cords are not authorized under carpet or in walkways.
- VEHICLES ON DISPLAY must have filler caps sealed and batteries must be disconnected. **VEHICLES BEING UNLOADED** must not be left with engines idling. A separate permit is required for motorized vehicles.
- HALOGEN LAMPS MUST BE IN UL OR RECOGNIZED LABORATORY APPROVED METALLIC FIXTURE Halogen lamps are limited to 35 watts and must be of the sealed variety, which prevents direct handling of the bulb. Certain forms of halogen lamps have been completely prohibited. Contact the South Point Catering Office for a current copy of the halogen ban statement.
- COMPRESSED GAS CYLINDERS, INCLUDING LPG, Helium, Oxygen, and Acetylene, are prohibited unless approved by the Office of Fire Protection and Safety. No cylinders will remain in the facility overnight.
- THE USE OR STORAGE OF FLAMMABLE OR COMBUSTIBLE LIQUIDS ARE PROHIBITED inside of the buildings, exceptions must be approved by South Point Management. Paint spraying must be done outside the building.
- Areas enclosed by solid walls and ceiling must be provided with **APPROVED SMOKE DETECTORS.**
- IN PLACES OF PUBLIC ASSEMBLY, any two-story booth with only one stairway must have a sign stating maximum occupancy - ten (10) people. Please be sure to check with Show Management as a separate permit may be required.

For questions or further information, you may visit www.clarkcountynv.gov/depts/fire or contact the South Point Catering Office.